

| | | Unique identification | code | of the product type: | | | | |
|--|--|-----------------------|-------|-------------------------|--|--|--|--|
| | 100-071-500M | | | | | | | |
| Type, batch or serial number or any other element allowing identification of the construction product as required: | | | | | | | | |
| | The type number of | of 100-071-500M : se | e the | print on the cable or s | ticker on the box | | | |
| Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer: | | | 4 | ivanie, registereu | trade name or registered trade mark and the manufacturer as required under Article 11(5): | | | |
| Supply of electricity and communication in buil civil engineering works with the objective o generation and spread of fire and sr | | of limiting the | | Electric A T F | Excel Excel House Inction Six Industrial Estate Avenue, Birmingham, UK, B6 7JJ iel : +44 (0)121 326 7557 ax : +44 (0)121 326 1537 : CPR@excel-networking.com | | | |
| | blicable, name and contact address tative whose mandate covers the ta Article 12(2): | | 6 | Oystern of Systems of | f assessment and verification of constancy of onstruction product as set out in CPR, Annex V: | | | |
| N/A | | | | | System 3 | | | |
| In case of the | he declaration of performance conc | erning a construction | proc | duct covered by a harm | nonized standard: | | | |
| Notified product certification body No. 0199 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance. | | | | | | | | |
| UK CA Notified product certification body No. 2661 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance. | | | | | | | | |
| Declared pe | erformance: | | | | | | | |
| Essential characteristics | | Performance | | | Harmonised technical specification | | | |

| Essential characteristics | Performance | Harmonised technical specification |
|---------------------------|--------------|------------------------------------|
| Reaction to fire | Dca s2 d2 a1 | C € EN 50575:2014+A1:2016 |
| Dangerous substances | None | UK BS EN 50575:2014+A1:2016 |

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signature: Neil Payne

Date: 06/05/2024

Neil Payne (Product Manager)