


Tuotetiedot							
Tuotekoodi	Tuotenimi	I_n Al	I_n Cu	U_n	I_{max} Al	I_{max} Cu	U_{max}
VC06-0018	Kojeliitin 2xAl/Cu 6-50	250 A	320 A	690 V	-	-	-

Asennus

Asennustapa **Ruuvi**





Kojeliittimien asennus sähkökojeeseen/laitteeseen suoritetaan ko. laitteen/kojeen valmistajan ohjeiden mukaisesti.

VC06-0018



Kytkeä

Ruuvin koko 	Kierre M10	Kiristysmomentti 6-10 mm ² 6 Nm 16-50 mm ² 10 Nm - - - -	Kuurintapituus (S ₁) L ₁ 18,5 mm (S ₂) L ₂ 32 mm 
	AV 5		
		Max. Johdin ala	50 mm²
Kuparijohtimet	Alumiinijohtimet	Sallitut IEC 60228 -johdintyytit	
Max. 3 X CU / Liitinaukko  ≤ 50 mm ² yhteensä	1 X AL / Liitinaukko  Liitosrasva: esim. Penetrox	Class 5 & 6 (hienosäikeinen) Suositellaan johdinpääholkkia Class 1 & 2 (yksi- ja muutamalankainen)	Sektorikaapeli  Muokkaa pyöreäksi

Johtimien asennus



Huom!



Samaan johdintilaan voidaan kytkeä enintään kolme vierekkäistä standardipoikkipinta alan kuparijohdinta. Johtimien yhteenlaskettu poikkipinta-ala ei saa ylittää liittimen max. johdon poikkipinta-alaa. Käytettäessä alumiinisia johtimia, saa johdintilaan kytkeä ainoastaan yhden johtimen, riippumatta sen poikkipinta-alasta.

Johdintaulukko, poikkipinta-ala ja johtimien määrä / kytkentila (Al-johtimien määrä suluisissa)

1,5 mm ²	2,5 mm ²	6 mm ²	10 mm ²	16 mm ²	25 mm ²	35 mm ²	50 mm ²	Taulukossa olevat johtimien määrät tarkoittavat vain tehdasmaisesti asennettuja liittimiä.
-	-	3	3	3 (1)	2 (1)	1 (1)	1 (1)	

Ouneva Oy

Teollisuustie 21
FI-82730 Tuupovaara, Finland

Tel. +358 400 179 750
info@ouneva.fi


www.ounevagroup.fi
www.ounevaproducts.fi

Product data

Product code	Product name	$I_{n\ Al}$	$I_{n\ Cu}$	U_n	$I_{max\ Al}$	$I_{max\ Cu}$	U_{max}
VC06-0018	Device connector 2xAl/Cu 6-50	250 A	320 A	690 V	-	-	-

Installation

Type	Screw
------	-------




The manufacturer made installation instructions of a specific device must be applied during the installation.

VC06-0018



Connection

Screw 	Thread	M10	Tightening torque 6-10 mm² 6 Nm 16-50 mm² 10 Nm - - - -	Stripping length (S ₁) L ₁ 18,5 mm (S ₂) L ₂ 32 mm 
	SW	5		
	Max. Wire cross section 50 mm²			
Copper conductors	Aluminium conductors	Supported IEC 60228 -conductors		Sector shaped cable
Max. 3 X CU / Conductor space  ≤ 50 mm² total	1 X AL / Conductor space  Anti-corrosion Paste: e.q. Penetrox	 Class 5 & 6 (fine stranded) Using ferrule is recommended Class 1 & 2 (solid and stranded)		 Pre-round the cable

Conductor installation



Attention!



It is allowed to use max. amount of three adjacent cross-sections in one space.(Copper conductors). The nominal max. cross-section value must not be exceeded. When using aluminium conductors, it is allowed to use only one conductor /space.

Cross-section of conductors and number of conductors / space. (Al-conductors in parenthesis)

1,5 mm²	2,5 mm²	6 mm²	10 mm²	16 mm²	25 mm²	35 mm²	50 mm²	Note! The specified amount of conductors refers only to industrially installed terminals.		
-	-	3	3	3 (1)	2 (1)	1 (1)	1 (1)			
			70 mm²	95 mm²	120 mm²	150 mm²	185 mm²	240 mm²	300 mm²	400 mm²
			-	-	-	-	-	-	-	-

Ouneva Oy

Teollisuustie 21
FI-82730 Tuupovaara, Finland

Tel. +358 400 179 750
info@ouneva.fi

www.ounevagroup.fi
www.ounevaproducts.fi