



CERTIFICATE FI/40473

Our Ref. HEL-CERT191100752-02

Product Connector for power cables

Type KE 54.2

Trademark ENSTO

Certificate Holder Ensto Finland Oy
Ensio Miettisen katu 2
FI-06150, Porvoo, Finland

Technical information Rated cross-section Al/Cu 35 – 240 mm²
Tightening torques:
35 - 70 mm² 12 Nm
95 – 240 mm² 40 Nm
In 425 A

Other information See the Appendix to this Certificate

The product is certified according to the following standard(s) EN 61238-1:2003
EN 60947-7-1:2009

Validity This certificate is valid until 26 November 2020 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 26 November 2019

SGS Fimko Ltd

Signature



Sixten Lökfors
Project Manager



SGS Fimko Ltd

Takomatie 8, FI-00380 Helsinki, Finland
t. +358 9 696 361 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Manufacturer

Ensto Finland Oy
Ensto Smart Buildings
Ensio Miettisen katu 2
FI-06150, Porvoo, Finland

Manufacturing site

Ensto Ensek AS
Keki tn. 1
EE-76606, Keila, Estonia

Additional information

Ability to receive Cu conductors
3: 35 mm²
3: 50 mm²
2: 70 mm²
1: 95 – 240 mm²

This certificate replaces Certificate FI 28770 dated 16 September 2014,
due to prolonged validity.

Based on:

298149-2, 277557-1