


ISOMETRIC VIEW
(EXTERNAL)



ISOMETRIC VIEW
(INTERNAL)

- NOTES:
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.

THIS SYSTEM BYPASS PANEL CAN BE USED WITH FOLLOWING UPS CONFIGURATIONS		
UPS SKU NUMBER / RATING	CONFIGURATION	SYSTEM RATING IN KW
GVSUPS40KH / 40KW	1+1	40
	2+0	80
GVSUPS50KH / 50KW	1+1	50
	2+0	100


THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric


TITLE: GALAXY VS
WALLMOUNT MAINTENANCE BYPASS PANEL
40/50KW, 3PH 400V TWO UNITS
ISOMETRIC VIEW

PROJECT: SUBMITTAL DRAWINGS SHEET 1 OF 5


DWG NO:	GVSBBPAR40K50H	REV.	1
DRAWN:	BALA	20-SEP-22	FIRST
ENGINEER:	JiaChen LIN	20-SEP-22	ANGLE
APPROVED:	J L / R I / H N	20-SEP-22	PROJECTION:




FRONT VIEW




LEFT SIDE VIEW



FRONT VIEW-WALLMOUNT DETAILS
(DOOR AND INTERNAL DETAILS NOT SHOWN)



TOP VIEW



BOTTOM VIEW

- NOTES:**
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. ALL DIMENSIONS ARE IN MILLIMETERS.
 4. CABLE ENTRY IS THROUGH THE BOTTOM OF UNIT.
 5. FRONT AND BOTTOM SERVICE ACCESS REQUIRED, RIGHT,LEFT SIDE VENTILATION CLEARANCES RECOMMENDED.
 6. NET WEIGHT OF THE UNIT IS 50kg.
 7. PROTECTION CLASS: IP20.
 8. PANEL COLOR: RAL 9003, GLOSS LEVEL 85%.
 9. OPERATING TEMPERATURE: 0°C TO 40°C.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TITLE: GALAXY VS
WALLMOUNT MAINTENANCE BYPASS PANEL
40/50KW, 3PH 400V TWO UNITS
GENERAL ARRANGEMENT

PROJECT: SUBMITTAL DRAWINGS **SHEET 2 OF 5**

DWG NO: GVSBPAR40K50H

DRAWN: BALA 20-SEP-22

ENGINEER: JiaChen LIN 20-SEP-22

APPROVED: J L / R I / H N 20-SEP-22


REV. 1

FIRST

ANGLE


PROJECTION:

INTERNAL DETAILS



INTERNAL FRONT VIEW
(FRONT DOOR AND COVER REMOVED)

POWER CIRCUIT DIAGRAM



NOTES:

1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
3. ALL DIMENSIONS ARE IN MILLIMETERS.
4. DASH-DOT (- . - . - .) LINES INSIDE OF MBP UNIT, REPRESENT PE-CONDUCTOR CONNECTION.
5. DASHED (- - -) LINES OUTSIDE OF MBP UNIT, REPRESENT CABLING PROVIDED BY OTHERS.
6. THE NEUTRAL JUMPERS MAKES A BOLTED CONNECTION OF THE NEUTRAL SO THAT THE NEUTRAL IS NOT DISCONNECTED WHEN THE 4-POL BREAKERS ARE OPENED. DO NOT REMOVE THE NEUTRAL JUMPERS UNLESS ALLOWED BY LOCAL REGULATIONS.
7. MAXIMUM ALLOWABLE INPUT CABLE AND LOAD CABLE SIZE IS 70 Sqmm.
8. MAXIMUM ALLOWABLE BYPASS INPUT AND OUTPUT CABLE SIZE IS 25 Sqmm.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TITLE: GALAXY VS
WALLMOUNT MAINTENANCE BYPASS PANEL
40/50KW, 3PH 400V TWO UNITS
INTERNAL VIEW AND POWER CIRCUIT

DWG NO: GVSBP40K50H

DRAWN:	BALA	20-SEP-22
--------	------	-----------

ENGINEER:	JiaChen LIN	20-SEP-22
-----------	-------------	-----------

PROJECT: SUBMITTAL DRAWINGS	SHEET 3 OF 5
-----------------------------	--------------

5	APPROVED: J L / R I / H N	20-SEP-22
---	---------------------------	-----------


REV. 2

FIRST

ANGLE

PROJECTION:

INTERFACE WIRING BETWEEN UPS AND SYSTEM BYPASS PANEL



- NOTES:**
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. CABLES BETWEEN UPSs AND SYSTEM BYPASS PANEL PROVIDED BY OTHERS.
 4. ROUTE THE CLASS 2/SELV CABLES SEPARATELY FROM THE NON-CLASS 2/NON-SELV CABLES.

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric


TITLE: GALAXY VS WALLMOUNT MAINTENANCE BYPASS PANEL 40/50KW, 3PH 400V TWO UNITS CONTROL CONNECTIONS

PROJECT: SUBMITTAL DRAWINGS **SHEET 4 OF 5**

DWG NO: GVSBBPAR40K50H

DRAWN: BALA	20-SEP-22
ENGINEER: JiaChen LIN	20-SEP-22
APPROVED: J L / R I / H N	20-SEP-22

REV. 2
FIRST ANGLE PROJECTION







FRONT ISOMETRIC VIEW-INTERNAL
(FRONT DOOR REMOVED)

POSSIBLE ASSOCIATIONS EASY UPS 3S	
3:3	3:1
2 x 10kVA	2 x 10kVA
2 x 15kVA	2 x 15kVA
2 x 20kVA	
2 x 30kVA	
2 x 40kVA	

For 3:1, use N & L1 only; L2 & L3 not used

INTERFACE DETAILS FOR GVS BYPASS PANEL TO USE WITH PARALLEL EASY 3S UPS 3:1 AND 3:3 (USE ONE OF THE METHODS SHOWN BELOW)



- NOTES:
1. INSTALLATION SHALL COMPLY WITH ALL APPLICABLE NATIONAL, STATE AND LOCAL ELECTRICAL REGULATIONS.
 2. PLEASE REFER TO PRODUCT MANUALS FOR ADDITIONAL DETAILS PRIOR TO INSTALLATION AND SITE PREPARATION WORK.
 3. CABLES BETWEEN UPS AND MAINTENANCE BYPASS PANEL ARE PROVIDED BY OTHERS.
 4. THERE IS NO DEDICATED INPUT CONTACT IN EASY 3S UPS FOR MBB. PROGRAMMABLE J5 AND J6 CONTACT TO BE CONFIGURED AS MAIN CB NO.
 5. ROUTE THE SIGNAL CABLES SEPARATELY FROM THE POWER CABLES AND ALSO ROUTE THE CLASS 2/SELV CABLES SEPARATELY FROM THE NON-CLASS 2/NON-SELV CABLES.

REMOVE 3x INDICATOR LAMPS INTERNAL CONNECTIONS AND CHANGE MBB AUX CONTACT CABLING FROM NC TO NO

THIS DRAWING AND SPECIFICATIONS HEREIN ARE THE PROPERTY OF SCHNEIDER ELECTRIC AND SHALL NOT BE COPIED, REPRODUCED OR USED IN WHOLE OR IN PART, AS THE BASIS FOR THE MANUFACTURE OR SALE OF ITEMS WITHOUT WRITTEN PERMISSION FROM SCHNEIDER ELECTRIC. THIS DRAWING IS BASED UPON LATEST AVAILABLE INFORMATION AND IS SUBJECT TO CHANGE WITHOUT NOTICE.

Schneider Electric

TITLE: GALAXY VS
WALLMOUNT MAINTENANCE BYPASS PANEL
3PH 400V TWO UNITS
INTERFACE DETAILS FOR EASY UPS 3S

PROJECT: SUBMITTAL DRAWINGS SHEET 5 OF 5

DWG NO: GVSBBPAR40K50H
DRAWN: JAYAPRAKASH
ENGINEER: Leon DU
APPROVED: HARISH R

REV. 0
20-SEP-22
20-SEP-22
20-SEP-22
FIRST ANGLE PROJECTION